



ALS Denmark A/S  
 Bakkegårdsvej 406 A  
 DK-3050 Humlebæk  
 Telefon: +45 4925 0770  
 www.alsglobal.dk

## ANALYSERAPPORT

Gunderød Vandværk  
 Karlebovej 44C  
 2980 Kokkedal  
 Att.: Vandservice

**Udskrevet:** 18-06-2015  
**Version:** 1  
**Modtaget:** 10-06-2015  
**Påbegyndt:** 10-06-2015  
**Ordrenr.:** 299044

**Sagsnavn:** Gunderød vv  
**Lokalitet:** Gunderød Vandværk  
**Prøvested:** Afgang værk  
**Prøve ID:** Prøvehane  
**Udtaget:** 10.06.2015 kl. 13:55:00  
**Prøvetype:** Drikkevand - Organiske mikroforureninger  
**Prøvetager:** LAB/NLU  
**Kunde:** Gunderød Vandværk, Karlebovej 44C, 2980 Kokkedal

| Prøvenr.:                                | 69462/15 |       |           |                         |
|--|----------|-------|-----------|-------------------------|
| Parameter                                | Resultat | Enhed | Metode    | Grænseværdi Afgang værk |
| <b>HS drikkevand</b>                     |          | -     | HS GC/MS  |                         |
| Benzen                                   | <0.020   | µg/l  | HS GC/MS  |                         |
| Toluen                                   | <0.020   | µg/l  | HS GC/MS  |                         |
| Ethylbenzen                              | <0.020   | µg/l  | HS GC/MS  |                         |
| Xylener                                  | <0.020   | µg/l  | HS GC/MS  |                         |
| Naphtalen                                | <0.020   | µg/l  | HS GC/MS  |                         |
| Trichlormethan (Chloroform)              | <0.020   | µg/l  | HS GC/MS  | 1                       |
| 1,1,1-trichlorethan                      | <0.020   | µg/l  | HS GC/MS  | 1                       |
| Tetrachlormethan                         | <0.020   | µg/l  | HS GC/MS  |                         |
| Trichlorethylen                          | <0.020   | µg/l  | HS GC/MS  | 1                       |
| Tetrachlorethylen                        | <0.020   | µg/l  | HS GC/MS  | 1                       |
| cis-1,2-dichlorethylen                   | <0.020   | µg/l  | HS GC/MS  | 1                       |
| 1,2-dichlorethan                         | <0.020   | µg/l  | HS GC/MS  | 1                       |
| <b>Pesticider, Drikkevand grundpakke</b> |          | -     | GC/LC/MS  |                         |
| Mechlorprop(MCPP)                        | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| MCPA                                     | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Dichlorprop(2,4-DP)                      | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| 2,4-D                                    | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Simazin                                  | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Atrazin                                  | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Dichlobenil                              | <0.010   | µg/l  | GC/MS/SIM | 0.1                     |
| 4-CPP, (4-Chlorprop)                     | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| 2,6-Dichlorprop (2,6-DCPP)               | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Desisopropylatrazin                      | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Desethylatrazin                          | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Hydroxyatrazin                           | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| 2,6-Dichlorbenzamid (BAM)                | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Bentazon                                 | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Hexazinon                                | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| ETU (Ethylenthiourea)                    | <0.010   | µg/l  | LC/MS/SIM |                         |
| Aminomethylphosphonsyre, AMPA            | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Desethylterbutylazin                     | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Glyphosat                                | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Hydroxysimazin                           | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| Desethyldeisopropylatrazin               | <0.010   | µg/l  | LC/MS/MS  | 0.1                     |
| Desethyl-hydroxy-atrazin                 | <0.010   | µg/l  | LC/MS/MS  | 0.1                     |
| Desisopropyl-hydroxy-atrazin             | <0.010   | µg/l  | LC/MS/MS  | 0.1                     |
| Didealkyl-hydroxy-atrazin                | <0.010   | µg/l  | LC/MS/MS  | 0.1                     |
| 2,6-dichlorbenzoesyre                    | <0.010   | µg/l  | LC/MS/MS  | 0.1                     |
| 4-nitrophenol                            | <0.010   | µg/l  | LC/MS/SIM | 0.1                     |
| 2,4-dichlorphenol                        | <0.010   | µg/l  | GC/MS     | 0.1                     |

side 1

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r).  
 Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger.  
 Oplysninger om måleusikkerhed findes på [www.alsglobal.dk](http://www.alsglobal.dk)

**Tegnforklaring:**  
 #: Ikke akkrediteret  
 <: mindre end >: Større end

